



2016 Possum Point Power Station ABC&E Pond Ash Removal Project

NAME: Whitey Pope

TITLE: Project Lead

DATE: 2/12/ 2016

Operation Time: 0700-1730 hours

- No safety and no environmental issues
- Weather Friday 32 Deg Mostly Cloudy
- Tomorrow's Forecast: 2/13/16 Saturday 27 deg Sunny
- Number of trucks on site E pond (4)
- Number of Excavators Operating in E pond Today (0)
- Number of on road dump trucks in ABC pond Today(0)
- Number of off road dump trucks in E pond Today(0)
- E pond 10/19/15 0 hauled to D pond = **0 Cy**
- A&C pond 10/19/15 0 hauled to D pond = **0 Cy**

ACTIVITIES:

- Time: 0600-1930 hours
 - Glover S107 fabricating a cover to allow access for hoses and electric leads for sump pumps, flagmen for PP road one lane MER VAC TK cleaning outfall end of seventy two inch line cleaning ten feet inside for the second plug installation.
 - APEX pumping water from ABC&E pond to D pond.
 - Moretrench installing wells in D pond, approximately 8:10AM I was notified one of the employees working on the barge had been injured see safety below.
 - Glover around twelve PM the first plug installed was found to have zero pounds of pressure on the air gage MER confined space personnel entered the S107 sump to observe the plug air pressure to inflate plug was unsuccessful cause of failure has not been determined.
 - GAI watching VAC TK off load in C pond
 - Glover MER VAC services Quantico creek end of the seventy two inch line have installed the second plug from S107 sump
-

Cleanup Activities:

Environmental:

SAFETY:

- Employee was injured around eight AM Mr. Marcell informed moretrench the employee had to be fitness for duty tested before returning to work and receive medical attention if needed employee was taken for testing and medical evaluation received five stitches and released .
- Accident report will follow.